

SANITARY AND INDUSTRIAL
WASTEWATER COLLECTION--
PUMPING STATIONS AND FORCE MAINS

DEPARTMENTS OF THE ARMY AND THE AIR FORCE
MARCH 1985

REPRODUCTION AUTHORIZATION/RESTRICTIONS

This manual has been prepared by or for the government and, except to the extent indicated below, is public property and not subject to copyright.

Copyrighted material included in the manual has been used with the knowledge and permission of the proprietors and is acknowledged as such at point of use. Anyone wishing to make further use of any copyrighted material, *by itself and apart from this text*, should seek necessary permission directly from the proprietors.

Reprints or republications of this manual should include a credit substantially as follows: "Joint Departments of the Army and Air Force, USA, Technical Manual TM 5-814-1/AFM 88-11, Volume 2, Sanitary and Industrial Wastewater Collection--Pumping Stations and Force Mains."

If the reprint or republication includes copyrighted material, the credit should also state: "Anyone wishing to make further use of copyrighted material, *by itself and apart from this text*, should seek necessary permission directly from the proprietors."

Technical Manual
 No. 5-814-2
 Air Force Manual
 AFM 88-11, Volume 2

DEPARTMENTS OF THE ARMY
 AND THE AIR FORCE

Washington, DC, 15 March 1985

**SANITARY AND INDUSTRIAL WASTEWATER COLLECTION-
 PUMPING STATIONS AND FORCE MAINS**

	<i>Paragraph</i>	<i>Page</i>
Chapter 1. GENERAL		
Purpose and scope.....	1-1	1-1
Special wastes	1-2	1-1
Pump Station alternatives	1-3	1-1
Chapter 2. LOCATION OF PUMPING STATIONS		
Service area.....	2-1	2-1
Site selection	2-2	2-1
Building and site requirements	2-3	2-1
Chapter 3. TYPE AND CAPACITY OF PUMPING STATIONS		
Required pumping capacity	3-1	3-1
Type of construction.....	3-2	3-1
Chapter 4. WASTEWATER PUMPING EQUIPMENT		
Wastewater pumps	4-1	4-1
Pump drives.....	4-2	4-2
Drive mechanisms	4-3	4-3
Pump speed controls.....	4-4	4-3
Chapter 5. PUMPING SYSTEM DESIGN		
Force main hydraulics.....	5-1	5-1
Pump analysis and selection	5-2	5-3
Wet well design.....	5-3	5-5
Pump controls and instrumentation	5-4	5-6
Surge phenomena.....	5-5	5-7
Screening and comminuting devices.....	5-6	5-9
Chapter 6. PIPING, VALVES AND APPURTENANCES		
Pipe materials, fittings, joints.....	6-1	6-1
Valves and appurtenances	6-2	6-2
Installation.....	6-3	6-2
Chapter 7. PUMP STATION COMPONENTS		
Construction requirements	7-1	7-1
Heating and ventilation.....	7-2	7-1
Electrical equipment and lighting.....	7-3	7-2
Standby power	7-4	7-2
Water supply	7-5	7-2
Flow measurement.....	7-6	7-2
Paints and protective coatings.....	7-7	7-3
Appendix A. References.....		A-1
Bibliography		BIBLIO-1

*This manual supersedes TM 5-814-2 dated 1 September 1958.

LIST OF FIGURES

Figure		Page
5-1.	Chart for Hazen-Williams formula	5-2
5-2.	Typical pump-system curves.....	5-5
5-3.	Pump suction connections to wet well	5-7

LIST OF TABLES

Table		Page
3-1.	Classification of pumping stations	3-1
5-1.	Minimum pump cycle times.....	5-6
5-2.	Required submergence depth to prevent vortexing	5-6
5-3.	Water hammer wave velocities	5-8

CHAPTER 1 GENERAL

1-1. Purpose and scope. This manual provides guidance, instructions and criteria for the design of sanitary and industrial wastewater pumping facilities at fixed Army and Air Force installations, and any applicable special projects. Facilities covered in this manual include pump and ejector stations required for (1) removal of sanitary and industrial wastes from remote or low lying areas of the installation which cannot be served hydraulically by gravity sewers, (2) controlled introduction and lifting of raw wastewater into the waste treatment plant, (3) transfer of recycled and bypassed flows throughout the plant, and (4) discharge of treated effluent. Pumping systems for the handling of sludge, grit and scum are presented in TM 5-814-3/AFM 88-11, Vol. 3. The design of a wastewater pumping station will typically include site improvements, structures, screening and flow monitoring devices, pumping units, pump drives, system controls and instrumentation, mechanical and electrical components, interior piping, underground force mains, valves and appurtenances.

1-2. Special wastes. Pumping systems for hazardous and explosive wastes, corrosive acids or alkalies, high temperature or other industrial type wastes, will generally require the selection of highly resistant pumps, valves and piping materials. Design of these systems will be in accordance with special criteria developed for the particular situation. Selection of materials for pumps, piping, valves and controls, etc., will be based on manufacturers' recommendations, product specifications, and any other appropriate design manuals or applicable criteria.

1-3. Pump stations alternatives

a. Gravity sewer system. Pumping stations and pneumatic ejectors will normally be required to remove wastes from areas which cannot be served hydraulically by gravity sewers. In certain situations however, a gravity sewer system can be utilized, but only at the

expense of deep trench excavation, jacking, boring, tunneling, or construction of long sewer runs to avoid high terrain. In those cases, both wastewater pumping and gravity flow sewers will be technically feasible and capable of meeting service requirements. However, they may not be equivalent in economic terms. When it is not readily apparent which solution would be more economical, the decision to use one or the other will be based on a life cycle cost analysis. Initial capital and construction costs for pumps, ejectors, structures, force mains, etc., plus operation and maintenance costs, will be compared with the costs of deep trench excavation, or other special construction methods required for a gravity system. Generally, a gravity sewer system will be justified until its cost exceeds the cost of a pumped system by 10 percent. TM 5-814-8 contains criteria for economic evaluation of wastewater pumping. TM 5814-1/AFM 88-11, Vol. 1 provides criteria for engineering and design of sanitary and industrial wastewater collection systems.

b. Grinder pumps and vacuum systems. There may be areas so limited by high groundwater, subsurface rock, unstable soil or steep topography, that neither gravity sewers nor centralized pumping stations will be feasible. In these cases, the use of grinder pumps or vacuum systems will be investigated. See paragraph 1-4b of TM 5-814-1/AFM 88-11, Vol. 1. Design criteria for grinder pumps are contained in this manual.

CHAPTER 2

LOCATION OF PUMPING STATIONS

2-1. Service area. The requirement that an area be served by a wastewater pumping facility will in most cases be determined by topography. Building and grade elevations in the area generally will be too low for proper gravity drainage to an existing or proposed sewer system, or waste treatment facility. Thus, collection and pumping of wastes from these low lying areas will be necessary. In addition to topographic considerations, natural boundaries like waterways, rivers, streams, etc., and property lines of Federal, state and local jurisdictions, also play a role in determining the size and limits of service areas.

2-2. Site selection. The location of pumping facilities within a service area will be based primarily on topographic considerations and the need to provide for future development. Pump stations will be located so that all points within the intended service area can be drained adequately by gravity sewers. Any planned development within the service area, such as construction of new buildings or modifications to existing ones, or any projected shifts in population and/or workforce will be considered. This type of information is generally obtained from the installation master plans, or from personnel staffing requirements. It is a relatively simple matter to design a pumping station with capacity for future development by providing room for additional or larger pumps, motors, impellers, etc. However, the physical location of the station is more critical since it cannot be moved to accommodate new buildings or population increases. The following general guidelines for site selection and location of pumping stations will be used:

- Pumping facilities will not be constructed beneath buildings, streets, roadways, railroads, aircraft aprons or runways, or other major surface structures, to the maximum extent practical.

- Pump stations will not be located closer than 500 feet to buildings, or other facilities to be occupied by humans, unless adequate measures are provided for odor and gas control.

- Pumping stations at wastewater treatment facilities will normally be located adjacent to, or in connection with, other plant elements as required for proper functioning of the treatment systems.

- The location of pumping stations will be made with proper consideration given to the availability of

required utilities such as electric power, potable water, fire protection, gas, steam and telephone service.

2-3. Building and site requirements

a. Floor and building elevations. The invert elevations of incoming sewers will determine the depths of underground portions (substructure) of the pumping station. It is common practice to set the maximum liquid level in the wet well equal to the 80-90 percent flow depth of the lowest incoming sewer. Subsurface and soil conditions at the site will dictate the structural design, excavation depths, and top of footing elevations required for the foundation. Surface conditions such as adjacent buildings and site grading will determine the elevations of floors above ground (superstructure), except that the elevation of the ground floor will be set above the maximum expected flood level.

b. Architectural and landscaping. For pumping stations located in built-up areas, the architectural exterior of the buildings should be made similar to, or compatible with, surrounding buildings. When the station is located in a remote area, building appearance is not important, but the possibility of future development in the vicinity will be considered. Pump stations and facilities will be provided with fencing where necessary to prevent vandalism, and to protect people from hazardous contact with electrical transformers and switching equipment. Landscaping should be considered in built-up areas, and will be required in residential communities. Where stations must be constructed in close proximity to residences or other quarters, buffer zones of planted shrubbery should be provided for noise reduction.

c. Access. All pump stations will be readily accessible from an improved road. For stations that are not enclosed, access will be provided for direct maintenance from a truck equipped with hoist attachments. For enclosed stations, provisions will be included in the structure to facilitate access for repair, and to provide a means for removal and loading of equipment onto a truck.

CHAPTER 3

TYPE AND CAPACITY OF PUMPING STATIONS

3-1. Required pumping capacity. Proper selection of the number and capacity of pumping units is dependent upon the quantity and variation of wastewater flows to be handled. Except as indicated below for small stations, pumping units will be selected to handle the normal daily range of wastewater flows generated in the service area. The number and capacity of pumps provided will be sufficient to discharge the minimum, average, peak daily and extreme peak flowrates as calculated in TM 5-814-1/AFM 88-11, Vol. 1. Pumping capacity will be adequate to discharge the peak flowrates with the largest pump out of service. Pumps utilized for treatment plant processes, recycling and bypassing of flows, etc., will be based on criteria developed in TM 5-8143/AFM 88-11, Vol. 3. Consideration will be given to future conditions which may occur during the life of the station. Normally, where future development and population increases are projected for the area, pumps will be designed for initial conditions only, and the station will be provided adequate room for expansion of pumping capacity at a later date. Expansion of pumping capacity can be accomplished with the installation of additional pumping units, larger pumps, impellers, drive units, adjustable or variable speed drives. However, some situations may warrant provision of capacity for future increases initially, for economic or other reasons. Each case will be analyzed individually.

a. Small stations. Pumping stations required for small remote areas which generate extreme peak flowrates of less than 700 gpm, and where the possibility of future expansion is unlikely, and grinder pump installations serving three or more buildings, will be provided with two identical pumping units. Each pumping unit will be of the constant speed type, and will be capable of discharging the extreme peak wastewater flowrate. The station will be designed to alternate between zero discharge and peak discharge. This arrangement will provide 100 percent standby capacity to allow for necessary maintenance and repairs. Pneumatic ejector stations will be provided with duplex ejectors each sized for the extreme peak flowrate.

b. Large stations. Pumping stations serving large areas of the installation, and especially stations where the entire wastewater flow or major portions thereof must be pumped to the treatment facility, will be designed so far as practicable to operate on a continuous basis. The rate of pumpage must change in increments as the inflow to the station varies. This

mode of operation will normally require two or more wastewater pumps of the constant or variable speed type, operating in single or multiple pump combinations, as required to match the incoming flowrates.

3-2. Type of construction. A classification of pumping stations by capacity and the method of construction normally utilized for that capacity is provided in Table 3-1. Factory assembled pumping stations, commonly referred to as package type stations, are manufactured in standard sizes and are shipped from the factory in modules with all equipment and components mounted, installed, and ready for connection. These type stations will be suitable for low flows, and where the need to protect pumps from clogging is minimal. Conventional field erected pumping stations are designed for a particular location and to meet specific requirements. Field constructed stations will be used where the quantity of flow or its variation, or both, exceeds the capacity of available factory assembled stations, or where site conditions require the use of special designs or construction methods.

Table 3-1. Classification of pumping stations.

Range Class/Type	Recommended Capacity Gallons Per Minute
Factory Assembled (Package Type)	
Pneumatic Ejectors	30-200
Wet Pit Submersible Pumps	100-500
Dry Pit Pumps	100-2,000
Conventional Field Erected	
Small	300-1,500
Intermediate	1,500-10,000
Large	over 10,000

Note: Package type, dry pit pump stations in the capacities shown are generally available off-the-shelf. However, station capacities up to 5,000 gallons per minute can be obtained by special order.

CHAPTER 4 WASTEWATER PUMPING EQUIPMENT

4-1. WASTEWATER PUMPS

a *Centrifugal pumps.* The centrifugal pump is the predominate type of wastewater pump used. These pumps are available in three variations, radial flow, mixed flow, and axial flow. Centrifugal pumps will not be used in capacities of less than 100 gallons per minute.

(1) Radial flow pumps. The radial flow centrifugal pump is the major type used for pumping raw wastes. In a radial flow pump, the fluid enters the impeller axially and is discharged at right angles to the shaft. Two types of radial flow pumps are available, single suction and double suction. In a single-end suction pump, fluid enters the impeller from one side. The shaft does not extend into the suction passage, and because of this, rags and trash do not clog the pump. The single-end suction pump will be suitable for handling untreated wastewater. For a double suction pump, fluid enters the impeller from both sides, however the shaft extends into the suction passage, thereby limiting its use to handling only clear water. Radial flow centrifugal pumps are available in discharge sizes of 2 to 20 inches. However, pumps with a capacity to pass 3-inch minimum solids will be required. The recommended capacity range for these pumps is 100 to 20,000 gpm. Pumps are available in discharge heads of 25 to 200 feet total dynamic head (TDH). Peak design efficiency ranges from 60 percent for smaller pumps to 85 percent for larger pumps. Radial flow pumps are suitable for either wet well or dry well applications. They can be installed with horizontal or vertical shafting, however, vertical shaft pumps require considerably less space.

(2) Mixed flow pumps. The mixed flow centrifugal pump is an intermediate design between the radial flow type and the axial flow type, and has operating characteristics of both. The mixed flow pump is designed with wide unobstructed passages, and is therefore suitable for handling wastewater or clear water. Mixed flow centrifugal pumps are available in 8-inch through 84-inch discharge sizes. The recommended capacity range for these pumps is 1,000 to 80,000 gpm. Pumps are available to operate at 10 to 60 feet TDH. Peak design efficiency depends on the size and characteristics of the individual pump, but generally ranges from 80 to 90 percent. The mixed flow centrifugal pump is normally used only in dry well applications, with either horizontal or vertical shafting configuration.

(3) Axial flow pumps. Axial flow centrifugal pumps will not be used to pump raw untreated wastewater. This pump is designed primarily for clear water service and for wet well installations. The pump is

furnished with vertical shaft having a bottom suction, with the propeller mounted near the bottom of the shaft and enclosed in a bowl. The propeller is totally submerged and can be clogged by large solids, rags or trash. Therefore, this pump will only be used for clear well applications. Axial flow centrifugal pumps are available in 8-inch through 72-inch discharge sizes. The recommended capacity range for these pumps is 500 to 100,000 gpm. Pumps are available to operate from 1 to 40 feet TDH.

(4) Pump construction. Centrifugal wastewater pumps will normally be constructed of cast iron with bronze or stainless steel trim, and with either cast iron or bronze impellers. When operating' ill wastewater containing substantial quantities of grit, impellers made of bronze, cast steel or stainless steel will be required. Enclosed impellers will be specified for wastewater pumps required to pass solids. Pump casings of the volute type will be used for pumping raw untreated wastes and wastewaters containing solids. Diffusion of turbine type casings may be utilized for effluent or clear water service at waste treatment facilities. Pump shafts will be high grade forged steel, and will be protected by renewable bronze or stainless steel sleeves where the shaft passes through the stuffing box. Stuffing boxes will utilize either packing glands or mechanical type seals.

(5) Stuffing box seals. The stuffing box will be lubricated and sealed against leakage of wastewater (into the box) by grease, potable water, or another clear fluid. The lubricating and sealing medium will be supplied to the stuffing box at a pressure of 5 to 10 psi greater than the pump shutoff head. Grease seals are usually provided by cartridges which are either spring loaded or pressurized by connections off the pump discharge. These arrangements generally do not maintain sufficient seal pressure on the stuffing box. However, they will be acceptable for low head pumps and where the wastewater contains little grit, as when pumping treated effluent. When pumping raw untreated wastes containing the usual quantities of grit, a potable water seal system with seal pump will be required if a potable water line is assessable within a reasonable distance. The Later seal system will be capable of supplying 3 gpm per pump minimum. The principal advantage of a water seal over a grease seal is the positive pressure maintained on the stuffing box by the seal pump, and small amount of water which flows from the stuffing box into the pump casing. Grit and other abrasive materials that may be in the wastewater are

thereby prevented from entering the stuffing box, thus reducing wear on the shaft and packing. The advantage of less frequent repairs to the shaft and less frequent repacking should be considered in relationship to the cost of providing the water line and other necessary facilities for the water seal. Where freezing of seal water is likely to occur, protective measures will be taken. There must not be, under any circumstances, a direct connection between wastewater pumps and the potable water system, nor any possibility of backflow of wastes into the potable water system. Air Force facilities will comply with AFM 85-21.

b. Screw pumps. The screw pump is classified as a positive displacement pump, and as such, maintains two distinct advantages over centrifugal pumps. It can pass large solids without clogging, and can operate over a wide range of flows with relatively good efficiencies. Screw pumps are normally available in capacities ranging from 150 to 50,000 gpm with a maximum lift of 30 feet. Because of its nonclog capabilities and wide pumping range, the screw pump is best suited for lifting raw untreated wastewater into the treatment facility, and for the pumping of treated effluent. Its use in sludge pumping is discussed in TM 5-814-3/AFM 88-11, Vol. 3. Also, when treatment plants are upgraded, screw pumps may be installed to overcome the additional head losses created by new treatment units, so that existing discharge facilities can be retained. Screw pumps are usually driven by a constant speed motor with gear reducer, and are inclined at angles of 30 to 38 degrees from the horizontal. In most instances, screw pumps will be installed outdoors with only the drive unit enclosed.

c. Pneumatic ejectors. Pneumatic ejector stations will generally be used only in remote areas where quantities of wastes are small, and where future increases in waste flows are projected to be minimal. A pneumatic ejector consists of a receiving tank, inlet and outlet check valves, air supply, and liquid level sensors. When the wastewater reaches a preset level in the receiver, air is forced in ejecting the wastewater. When the discharge cycle is complete, the air is shut off and wastewater flows through the inlet into the receiver. Generally, duplex ejectors operate on a 1-minute cycle, filling for 30 seconds and discharging for 30 seconds. Thus, each receiver tank will be equal in volume to 30 seconds of the extreme peak flowrate. Pneumatic ejector stations are available in capacities ranging from 30 to 200 gpm with recommended operating heads up to 60 feet TDH. A typical ejector installation will include duplex units with two compressors, receivers, level sensors, etc.

d Grinder pumps. Grinder pumps shred solids normally found in domestic wastewater, including rags, paper and plastic, into a slurry. The slurry can be

pumped under low head through pressure sewers as small as 1¼ inches in diameter. Grinder pumps are for submersible installation, with a recommended operating range of 10 to 100 gpm. These pumps are available in discharge heads of 10 to 150 feet TDH. The peak design efficiency is generally very low. Grinder pumps will be used only to handle domestic type wastes from one or more individual buildings, and only in remote areas or areas where gravity sewers and centralized pumping facilities are not feasible (see paragraph 1-3b).

4-2. Pump drives

a Electric motors. As a general rule, electric motors will be provided as the primary drive unit in sanitary and industrial wastewater pumping stations. Small pump stations serving remote areas where electric power is not available, will usually require engine drives. The three types of electric motors most commonly used in wastewater pumping are (1) squirrel-cage induction, (2) wound-rotor induction, and (3) synchronous. Squirrel-cage induction motors will normally be selected for constant speed pump applications because of their simplicity, reliability and economy. They can also be used for variable speed operation when provided with the proper speed control. Synchronous motors may be more economical for large capacity, low rpm, constant speed pumps. Wound-rotor induction motors are most commonly used for pumps requiring variable speed operation. For a 60 cycle, alternating current power supply, the maximum synchronous motor speed allowed for wastewater pumps will be 1800 rpm (approximately 1770 rpm induction speed). The normal range of speeds is from 600 to 1200 rpm, with speeds below 450 rpm unusual at military installations. Lower speed pumps and motors are larger and more expensive, but generally are more reliable. The selection of electric motors will depend upon the type, size and location of the pumps, type of speed control used, and the power available at the site. Pump location will determine the type of motor enclosure. For dry pit pump installations, motor enclosures will normally be the open, drip proof type. Pumps installed outdoors, or in dirty or corrosive environments, will require totally enclosed motors. Submersible pumps will have motor enclosures which are watertight. Motors installed outdoors will have temperature ratings adjusted to suit ambient operating conditions. For pumps designed to operate on an intermittent basis, space heaters will be provided in motor housings to prevent condensation. Motors installed in wet wells will be explosion proof. Motor starting equipment will be selected in accordance with paragraph 7-3, and will be suitable for the type of motor

required voltage. Motor starters will be designed for limiting the inrush current where shocks or disruptions to the electrical supply are likely to occur as a result of pump start-up. Where low starting inrush current is required for constant speed pumps, such as when using engine driven generator sets, wound-rotor motors will be considered as an alternative to squirrel-cage motors. The voltage required for operation of motors and other equipment will be determined in accordance with paragraph 7-3.

b Internal combustion engines. Internal combustion (I.C.) engines will be used primarily at large pumping stations where electric motors are the primary drive units, and where emergency standby facilities are required. Conditions which dictate the use of fixed, standby power at wastewater pumping stations are outlined in paragraph 7-4. I.C. engines will be required for small pump stations in remote locations where no electric power source exists. At large wastewater treatment plants where abundant digester gas is produced, it will generally be more feasible to use I.C. engines which are fueled by the waste gas. I.C. engines may be arranged to drive horizontal pumps by direct or belt connections, or they may drive vertical pumps through a right angle gear drive with an electric motor as the primary drive unit (dual drive). It is more common however, and will be the general rule at large pump stations, to provide fixed emergency generator sets powered by I.C. engines. Generators produce electric power not only for pumps, but also for auxiliary equipment such as heaters, lights, alarms, etc., and for critical pump control systems. The types of internal combustion engines normally used include (1) diesel, (2) gasoline, (3) natural gas, primarily digester gas, and (4) dual-fuel diesel. The use of gasoline engines for anything except small, remotely located pumping stations is not recommended due to the hazards associated with fuel handling and storage. Dual-fuel diesel engines fire a mixture of diesel oil and natural gas, with a minimum of 10 percent diesel fuel required to ignite the mixture. Propane is usually provided as a backup fuel for gas and dual-fuel diesel units. The selection of I.C. engines will be coordinated with the installation's Facility Engineer to insure that adequate operation and maintenance can be made available.

4-3. Drive mechanisms

a Direct drive. Direct drive, with the shaft of the drive unit directly connected to the pump shaft, is the most common configuration. This connection can be either close-coupled or flexible-coupled. When using a close-coupled connection, the pump is mounted directly on the drive shaft. This is the normal arrangement for a vertical pump driven by an electric motor. A horizontal pump will usually have a flexible connection, with the

engine mounted adjacent to the pump. A vertical motor mounted above, and at a distance from a vertical pump, will be connected to the pump with one or more lengths of flexible shafting. Direct drive offers the most efficient operation because no power is lost between the drive unit and the pump.

b Belt drive. Belt drives may be utilized if the pump speed is different from those available with standard drive units, or if speed adjustment is required. Speed adjustment is accomplished by changing pulley or sheave ratios. Belt drives used with horizontal pumps require more floor space than a direct drive unit. There is power loss through the belt, which results in lower efficiency, and belt wear increases maintenance requirements. Belt drives will be used only when it is not possible to choose single speed equipment to cover service conditions, or where pump speed adjustments may be required, but variable speed operation is not.

c Right angle drive. Right angle drives will be used on vertical pumps being driven by horizontal engines. If the engine serves as emergency standby, a combination gear box will be installed on the angle drive to allow operation of the pump by the primary drive unit, which is normally an electric motor. A clutch or disconnect coupling disengages the right angle gear when the motor drives the pump. When the engine drives the pump, the clutch is engaged and the motor rotates freely. In case of a power failure the engine is automatically started, and after reaching partial operating speed is engaged to drive the pump.

4-4. Pump speed controls

a Mode of operation. Wastewater pumps will be designed to operate in one of the following modes: (1) constant speed, (2) adjustable speed, or (3) variable speed. The type of speed control system will be selected accordingly. As indicated in paragraph 4-2a, the type of speed control required will influence the type of electric motor to be used.

(1) Constant speed. Constant speed drive is the simplest, most reliable, and most economical mode of operation, and will be suitable for the majority of wastewater pumping applications at military installations. However, where there is a need to match pumping rates with the incoming wastewater flowrates, a variable speed drive will usually be more appropriate.

(2) Adjustable speed. By changing pulley or sprocket ratios on a belt driven pump, the speeds can be adjusted to accommodate several constant speed pumping rates. This type of system will be used mainly in sludge pumping, but can be a good alternative

to variable speed control in wastewater pumping when speed adjustment is not required too often. Where automatic operation is needed pulleys or sheaves can be positioned through the use of pneumatic, hydraulic or electric devices.

(3) Variable speed. Variable speed operation will usually be required at large pumping stations where the entire wastewater flow, or major portions thereof, must be pumped to the treatment facility, and where it is desired to match the incoming flowrates in order to maintain a smooth, continuous flow into the plant. Pumping stations will normally require more pumps under a constant speed system than one utilizing variable speeds. Also, the size of the wet well can be reduced greatly when pumps operate on a continuous basis. Variable speed operation is less efficient than constant speed when pumping at reduced rates, however friction losses and thus power costs are generally less for the smaller flows.

b Speed control systems. The selection and design of the speed control system will be coordinated closely with the selection of the pump and drive units. The simplest system which allows pumps to accomplish the required hydraulic effects will be chosen for design. Factors to be considered in selecting a system include cost, efficiency, reliability, structural requirements, ease of operation and degree of maintenance necessary. The last two items are critical at military installations where adequate personnel cannot always be provided. Pumping stations will normally be designed for automatic on/off operation of the pumping units, with manual override by pushbutton or selector switch.

(1) Constant and adjustable speed. Most automatic constant speed and adjustable speed systems will operate from level signals. Pumps are turned on as the liquid level in the wet well rises, and are turned off when it falls. Pumping systems utilized in treatment plant processes are sometimes controlled by flow or pressure sensors. Level detection systems in standard use include the following:

(a) Float switches. The simplest type of switch consists of a float attached to a rod or tape, and suspended in the wet well. The float rod opens or closes a switch, depending on the rise or fall of the float riding on the liquid level. The float may also be suspended in a tube or cage. These units usually require frequent maintenance as grease, scum and debris in the wastewater build up on the equipment. Another type of float control incorporates a mercury switch encapsulated in a corrosion resistant ball, and suspended by cable in the wet well. This unit is not dependent upon the smooth, vertical movement of a rod, and thus is not subject to the maintenance problems described above.

(b) Bubbler tube. One of the most commonly used systems employs a bubbler tube which is suspended in the wet well and is fed by compressed air. The backpressure on the open end of the tube is sensed by pressure switches, and then transduced to a voltage or current signal. These signals are transmitted to a controller which operates the pumps. This system has no moving parts in contact with the wastewater, and requires very little maintenance. The constant flow of compressed air keeps the tube free of solids accumulations.

(c) Electrodes. A series of electrodes are mounted at different elevations so that when the liquid level rises and contacts an electrode, an electric circuit is energized. Electrodes are used primarily in pneumatic ejectors where the compressed air serves to keep the electrodes clean. They will not normally be used in wet wells due to frequent fouling by grease and waste debris.

(d) Sonic meters. A sonic meter measures the distance from the liquid level to the meter. They are difficult to install free of obstructions, and must be isolated from stray electrical or acoustic signals.

(e) Capacitance tubes and pressure diaphragm sensors. These types of controls will not normally be used due to fouling by the wastes.

(2) Variable speed. A bubbler system will in most cases be employed to control the operation of automatic variable speed pumps. In these systems, the backpressure from the bubbler tube is transduced to a pneumatic or electronic signal for use in on/off and variable speed control of the pumps. On/ off controls are usually provided by pressure or electronic switches. Variable speed control devices consist of (1) magnetic (eddy current) clutches, (2) liquid clutches, (3) variable voltage controls, (4) variable frequency controls, and (5) wound-rotor motor controls. Magnetic and liquid clutches have been available for many years as controllers for variable speed pumps. These older methods are inefficient in that the slip losses which developed are lost as heat. The recent development of solid state electronics has led to the introduction of newer methods of variable speed control suitable for both squirrel-cage and wound-rotor induction motors. The variable voltage and variable frequency controls are suitable for use with squirrel-cage motors. Variable frequency drives are possible in efficiencies up to 95 percent, and are available in sizes up to 250 hp. However, variable voltage units are inefficient and are not recommended. Wound-rotor motor controls come in five categories, (1) fixed step resistors, (2) liquid rheostats, (3) reactance/resistance controllers, (4) electronic rheostats, and (5) regenerative secondary controls. Of these, the regenerative secondary

control offers the best efficiency, while the other units are considerably less efficient and require more maintenance. In general, variable speed control devices are more expensive, less efficient, and require

a higher degree of maintenance than constant speed controls.

CHAPTER 5 PUMPING SYSTEM DESIGN

5-1. Force main hydraulics

a. General. The pipeline which receives wastewater from a pumping station, and conveys it to the point of discharge, is called a force main. Force mains will be designed as pressure pipe, and must be adequate in strength to withstand an internal operating pressure equal to the pump discharge head, plus an allowance for transient pressures caused by water hammer. The internal operating pressure is maximum at the pumping station, and is reduced by friction to atmospheric, or near atmospheric, at the point of force main discharge. The primary consideration in the hydraulic design of force mains is to select a pipe size which will provide the required minimum velocities without creating excessive energy losses due to pipe friction. The most economical size of force main should be determined on the basis of power costs required for pumping, and capital investment costs of piping and equipment. In practice however, the size is usually governed by the need to maintain minimum velocities at low flows to prevent deposition of solids, and to develop sufficient velocity at least once a day to resuspend any solids which may have settled in the line. However, regardless of pipe sizes required for minimum velocities, the minimum diameters to be used are 1Y4-inch for pressure sewers at grinder pump installations, 4-inch for force mains serving small pump stations and pneumatic ejectors, and 6-inch for all other force mains.

b Design formula and chart. Force mains will be designed hydraulically with the use of the Hazen-Williams formula as follows:

$$V = 1.32 C R^{0.63} S^{0.54}$$

where


V = velocity in feet per second

C = coefficient of pipe roughness

R = hydraulic radius in feet, and

S = slope of energy grade line in feet per foot

(1) Roughness coefficient. Values of C to be used in the formula range from 100 for older force mains which have been in service a number of years (usually over 10), to 140 for force mains which are newly constructed. Some manufacturers of plastic and asbestos-cement pipe report C values as high as 150. However, due to uncertainties in design and construction, plus a desire to provide a margin of safety, C values greater than 140 will not normally be permitted. At some installations, force mains may be very old (40 to 50 years) and in extremely bad condition, with offset joints broken pipe, or materials encrusted on pipe walls. For these cases, lower C values may be justified. However, values lower than 80 will not be allowed unless verified by flow and pressure tests. A solution to the Hazen-Williams formula is given in figure 5-1.



Source: Design and Construction of Sanitary and Storm Sewers WPCF Manual of Practice No. 9 by Water Pollution Control Federation, 1970, p. 83.

Figure 5-1. Chart for Hazen-Williams formula.

(2) Velocity. Velocity criteria for force mains are based on the fact that suspended organic solids do not settle out at a velocity of 2.0 foot per second or greater. Solids will settle at velocities less than 1.0 fps and when wastewater pumps are idle. However, a velocity of 2.5 to 3.5 fps is generally adequate to resuspend and flush the solids from the line. Force mains serving small pump stations, which are designed to operate on an intermittent basis, will be sized to provide a minimum velocity of 3.5 fps at the peak discharge rate. For small stations having flows too low

to warrant a minimum velocity of 3.5 fps with one pump operating, the design may call for both pumps to be operated manually once a week for a sufficient period of time to flush out the line. Larger stations having three or more pumping units, which operate a major portion of the time, will require minimum force main velocities ranging from 2.0 fps with one pump operating, to 5.0 fps with several pumps operating. In these cases, it is only required

that a minimum velocity of 2.5 to 3.5 fps be provided once or twice daily. Large pumping stations which serve the entire installation or major portions thereof, and which are designed to pump continuously, will usually have a greater number of pumps operating over a wider range of flowrates. Since the pumping range may vary from 7 or 8 to 1, it will generally be sufficient to design for velocities of 0.5 up to 7.0 or 8.0 fps. Maximum velocity is set at 10.0 fps.

(3) Slope. The value of S in the formula is equivalent to the kinetic energy loss due to pipe friction divided by the length of conduit, or $S = H_f/L$. Minor energy losses from fittings and valves will be converted to equivalent lengths of conduit for use in the formula. Conversion tables for fittings and valves can be found in standard hydraulics textbooks. The total kinetic energy loss in a force main will be computed by multiplying the slope of the energy grade line by the total length of conduit including equivalent lengths, or $H_f = S \times L$.

5-2. Pump analysis and selection

a. *Total dynamic head.* The head in feet against which a pump must work when wastewater is being discharged is termed the total dynamic head (TDH). The two primary components of TDH in wastewater applications are the static discharge head and the kinetic losses due to pipe friction. Velocity and pressure heads are also present, but are usually insignificant. The TDH will be calculated with the use of the Bernoulli energy equation which can be written as follows:

$$TDH = (P_d/W + V_d^2/2g + Z_d) - (P_g/W + V_g^2/2g + Z_g) + H_f$$

where

P_d, P_g = gage pressures in pounds per square foot

V_d, V_g = velocities in feet per second

Z_d, Z_g = static elevations in feet

H_f = kinetic energy loss from pipe friction, fittings, and valves, as calculated in paragraph 5-1b (3).

w = specific weight of fluid in pounds per cubic foot, and

g = acceleration due to gravity 32.2 ft/sec²)

All head terms are in feet. Subscripts d and g represent force main discharge and pump suction, respectively. In order to determine hydraulic conditions at the pump suction, it will be necessary to write an energy equation from the liquid level in the wet well to the pump suction nozzle.

b. *System head-capacity curve.* To determine the head required of a pump, or group of pumps, that would discharge at various flowrates into a force main system, a head-capacity curve must be prepared. This curve is a graphic representation of the total dynamic head, and will be constructed by plotting the TDH over a range of flowrates from zero to the maximum expected value. Friction losses can be expected to increase with time, thus affecting the capacity of the pumping units and their operation. Therefore, system curves will reflect the maximum and minimum friction losses to be expected during the lifetime of the pumping units, as well as high and low wet well levels. The typical set of system curves will generally consist of two curves using a Hazen-Williams coefficient of $C = 100$ (one for maximum and one for minimum static head), and two curves using a Hazen-Williams co-efficient of $C = 140$ (for maximum and minimum static head). These coefficients represent the extremes normally found in wastewater applications.

c. *Pump head-capacity curve.* The head that a particular pump can produce at various flowrates is established in pump tests conducted by the pump manufacturer. The results of these tests are plotted on a graph to form the pump characteristic curve. Along with the discharge head developed, the pumps operating efficiency, required power input, and net positive suction head are generally included on the same diagram.

(1) Efficiency and power input. Pump efficiency is the ratio of the useful power output to the input, or brake horsepower, and is given by:

$$E = \frac{wQ \text{ TDH}}{(\text{bhp})(550)}$$

where

E = pump efficiency (100 E = percent)

w = specific weight of fluid in pounds per cubic foot

Q = pump capacity in cubic feet per second

TDH = Total dynamic head, and
bhp = brake horsepower

Pump efficiencies usually range from 60 to 85 percent. Most characteristic curves will indicate a best efficiency point (BEP) at which pump operation is most efficient. Where possible, pumps will be selected to operate within a range of 60 to 120 percent of the BEP.

(2) Net positive suction head. When pumps operate at high speeds and at capacities greater than the BEP, the potential exists for pump cavitation. Cavitation can reduce pumping capacity and may in time damage the pump impeller. Cavitation occurs when

the absolute pressure at the pump inlet drops below the vapor pressure of the fluid being pumped. To determine if cavitation will be a problem, the net positive suction head (NPSH) available will be computed, and compared with the NPSH required by the pump. The NPSH is not normally a problem when discharge heads are less than 60 feet. However, when heads are greater than 60 feet, or when the pump operates under a suction lift, or far out on its curve, the NPSH will be checked. The NPSH available at the eye of the impeller in feet will be calculated with the following formula:

$$\text{NPSH}_A = H_8 + P_a/w - P_v/w$$

where

H_8 = total energy head at pump suction nozzle

$$= P_8/w + V^2/2g + Z,$$

P_a = atmospheric pressure in pounds per square foot absolute, and

P_v = vapor pressure of fluid being pumped in pounds per square foot absolute

All head terms are in feet.

(3) Affinity laws. A set of relationships derived from flow, head and power coefficients for centrifugal pumps, can be used to determine the effect of speed changes on a particular pump. These relationships are known as affinity laws and are as follows:

$$Q_1/Q_2 = N_1/N_2$$

$$H_1/H_2 = N_1^2/N_2^2$$

$$P_1/P_2 = N_1^3/N_2^3$$

where

N_1, N_2 = pump speeds in revolutions per minute (rpm)


Q, H and P terms represent pump capacity, discharge head, and power output respectively, at speeds N_1 and N_2 . These relationships will be used in analyzing

variable speed pump operation in the absence of manufacturer's characteristic curves, or where characteristic curves do not show performance at the desired speeds.

d Pump selection. System analysis for a pumping station will be conducted to select the most suitable pumping units which will meet service requirements, and to determine their operating points, efficiencies, and required horsepower.

(1) Single pump operation. A system head-capacity curve will be prepared showing all conditions under which the pump is required to operate. The system curve will then be superimposed onto a pump head-capacity curve, or characteristic curve, to define the pump operating point. The point where the two curves intersect represents the head and capacity at which the pump will operate in the given piping system.

(2) Multiple pump operation. Where two or more pumps discharge into a common header, the head losses in individual suction and discharge lines will be omitted from the system head-capacity curve. This is because the pumping capacity of each unit will vary depending upon which units are in operation. In order to obtain a true picture of the output from a multiple pump installation, the individual suction and discharge losses are deducted from the pump characteristic curves. This provides a modified curve which represents pump performance at the point of connection to the discharge header. Multiple pump performance will be determined by adding the capacity for points of equal head from the modified curve. The intersection of the modified individual and combined pump curves with the system curves shows total discharge capacity for each of the several possible combinations. Pumps will be selected so that the total required capacity of the pump installation can be delivered with the minimum level in the wet well and maximum friction in the discharge line. Pump efficiency will be a maximum at average operating conditions. A typical set of system curves with pump characteristic curves is shown in figure 5-2.



U.S. Army Corps of Engineers

Figure 5-2. Typical pump-system curves.

5-3. Wet well design

a *General.* Wet wells will be constructed at pumping stations for the purpose of storing wastewater flows prior to pump operation. The storage volume required depends upon the method of pump operation, i.e., whether pumps are constant, adjustable or variable speed. In addition to providing adequate storage volume, wet wells will be designed to (1) allow for proper pump and level controls, (2) maintain sufficient submergence of the pump suction inlet, (3) prevent excessive deposition of solids, and (4) provide ventilation of incoming sewer gases. In smaller stations, bar racks or comminuting devices may be installed within the wet well in order to reduce costs. Overflows from wet wells are prohibited in all cases.

b *Storage volume.* If pumps are of constant or adjustable speed type, the wet well volume must be large enough to prevent short cycling of pump motors.

For pumps driven by variable speed drives, the storage volume may be small provided pumping rates closely match the incoming flowrates. The volume required for the wet well will be computed with the following formula:

$$V = tq/4$$

where

V = required volume in gallons between start and stop elevations for a single pump, or a single speed step increase for adjustable or variable speed operation

t = minimum time in minutes of one pumping cycle (time between successive pump starts), or time required for a speed or capacity change, and
 q = pumping capacity, or increment in capacity where one or more pumps are operating and an additional pump is started, or where pump speed is increased, in gallons per minute

Constant or adjustable speed pumps driven by squirrel-cage induction motors will be designed for minimum cycle times as shown in the following table.

Table 5-1. Minimum pump cycle times.

More size, bhp	t, minutes
Less than 20	10 to 15
20 to 100	15 to 20
100 to 250	20 to 30
Over 250	as recommended by manufacturer

The storage volume calculated for small stations (capacities less than 700 gpm) which utilize two identical constant speed pumps, may be reduced one half by providing a control circuit to automatically alternate the pumps. The storage volume required for variable speed pumps will be based on providing sufficient time for a change in capacity when a pump is started or stopped. When a pump is started, the motor must be ramped to the desired speed, and the pumps already in operation must be reduced in speed. The time required for this is usually less than 1 minute. A considerable amount of storage is normally available in large sewers which serve stations utilizing variable speed pumps. This volume may be considered in design by calculating backwater curves for the various operating levels. The maximum retention time in the wet well will not exceed 30 minutes to prevent septicity.

c. *Suction pipe connections.* Pump suction piping will be selected to provide a velocity of 4 to 6 feet per second. Pipe should be one or two sizes larger than the pump suction nozzle. Vertical pumps installed in a dry well which is adjacent to the wet well, will be fitted with a 90 degree suction elbow, followed by an eccentric reducer and a gate valve. The suction line will be extended through the wall into the wet well, and terminated with either a 90 or 45 degree flared elbow, or an elbow with a flared fitting. The most commonly used piping arrangements are illustrated in figure 5-3, where D is the diameter of the flared inlet, and S is the submergence depth.

Adequate submergence of the suction inlet is critical to prevent air from being drawn in by vortexing. Minimum required submergence depths are given in table 5-2 as a function of velocity. The net positive suction head (NPSH) will also be considered when determining S. See paragraph 5-2c (2).

Table 5-2. Required submergence depth to prevent vortexing.

Velocity at diameter D, fps	S, feet
2	1.0
4	2.6
5	3.4
6	4.5
7	5.7
8	7.1

Larger, conventional type pump stations will normally be constructed with wet wells divided into two or more sections, or compartments, so that a portion of the station can be taken out of service for inspection or maintenance. Each compartment will have individual suction pipes, and will be interconnected with slide or sluice gates. The floor of the wet well will be level from the wall to a point 12 to 18 inches beyond the outer edge of the suction bell, and then will be sloped upward at a minimum 1:1 slope.


5-4. Pump controls and instrumentation

a. *General.* Instrumentation at a pumping station includes automatic and manual controls used to sequence the operation of pumps, and alarms for indicating malfunctions in the pumping system. Automatic control of pumps will usually be based on the liquid level in the wet well. Paragraph 4-4 contains a discussion of the various modes of pump operation, pump control systems, and a description of level detection devices. Manual control of pumps is always required in order to operate the pumps during emergencies, for maintenance purposes, or when automatic systems fail. Manual override will be set to bypass the low level cut-off, but not the low level alarm.

b. *Selection of control points.* A control range of at least 3.0 feet is required between maximum and minimum liquid levels in the wet well. A minimum of 6 inches will be required between pump control points used to start and stop successive pumps, or to change pump speeds. For small stations, the control range may be less, however control points will not be set closer than 3 inches.

(1) Constant or adjustable speed pumps require simple on-off switches to start or stop pumps, or to change from one speed step to the next.

(2) Variable speed pumps require a more complex control arrangement. The two basic types of level control for variable speed operation are (a) variable level, and (b) constant level. For variable level control, a narrow band of control points is established in the wet well. Pump speed is then adjusted in steps by the level detection system (usually a bubbler tube) as the level varies. Pumps operate at maximum



Source: Wastewater Engineering: Collection and Pumping of Wastewater by Metcalf & Eddy, Inc., 1981, p. 360.

Figure 5-3. Pump suction connections to wet well.

speeds near the HWL, and at minimum speeds near the LWL. However, pumps are started and stopped by level switches. Constant level control is seldom used, but may be required where a very narrow band of operation is necessary. In a constant level system, one level is set as the control point, and pump speed is adjusted in a stepless fashion as the liquid level rises above, or falls below this point.

c. *Alarms.* Alarms will be provided to signal high and low liquid levels in the wet well, pump failure, or a malfunctioning speed control system. The high level alarm will be set above the start point of the last pump in the operational sequence, but below the start point of the standby pump, if used. The low level alarm will be set below the shutoff point of the lead pump. An emergency, low level pump cutoff will be set below the low level alarm.

5-5. Surge phenomena

a. *Water hammer.* Sudden changes in flow and velocity in force mains can occur as a result of pump startup, pump shutdown, power failure, or rapid closing of a valve. These velocity changes can produce large pressure increases or surge phenomena known as water hammer. The most severe water hammer conditions are usually caused by a pump shutdown or power failure. An analysis of water hammer will include calculating the critical time, determining the maximum pressure increase, and selecting a method of control.

b. *Critical time.* When flow is suddenly changed in a force main, a pressure wave is generated which rapidly travels the entire length of conduit, and back

to the point of change. The time required for this roundtrip is given by:

$$T_c = 2L/a$$

where

T_c = critical time in seconds

L = length of force main between point of flow change and point of discharge in feet, and

a = velocity of pressure wave in feet per second

When flow is completely stopped ($Q = 0$) in a time interval greater than T_c , the maximum theoretical pressure increase is not fully developed. However, when flow is stopped in a time interval less than or equal to T_c , the change is said to be instantaneous, and the maximum pressure increase is developed as given below.

c. *Maximum pressure increase.* The maximum theoretical pressure increase or surge caused by water hammer is calculated from the following:

$$h_w = aV/g$$

where

h_w = pressure increase in feet

V = velocity of fluid in the pipeline prior to flow change in feet per second

g = acceleration due to gravity, or 32.2 ft/sec² at sea level, and

a = velocity of pressure wave in feet per second

Some typical values of a are given in table 5-3 below.

Table 5-3. Water hammer wave velocities.

Pipe Material	a , ft/sec
Asbestos-cement	2700--400
Ductile iron	3100--4200
Steel	2700--3900
Concrete	3300--3800
Plastic	1100--1500
Fiberglass	1200--1600

d. *Methods of control.* Whenever a pump is shut down, or power to the station fails, the pump motor is suddenly cut off. Pump speed along with flow and velocity in the force main are quickly decelerated by pressure waves, which travel up the pipeline and back in accordance with Newton's second law of motion. When the velocity is reduced to zero, reverse flow through the pump would occur if a gravity operated check valve or an automatic control valve were not installed on the pump discharge line, and did not close properly. Reverse flow fully accelerated through the pump could cause transient flows and pressures well above maximum design conditions. A swing check valve which stuck open temporarily, and then slammed shut under these conditions, would re5-8 suit in a large pressure surge as given by paragraph c above. In order

to control and limit these surge phenomena, the following practices will be followed.

(1) Gravity check valves. For simple cases involving small to medium sized pump stations with gradually rising force mains (no intermediate high points) of less than 1000 feet in length, and with static discharge heads of less than 50 feet, a gravity operated check valve will usually be sufficient. Gravity type check valves may be either swing checks utilizing outside lever and weight (or spring) set to assist closure, or then may be ball checks. Swing check valves are usually installed horizontally, while ball check valves may be either vertical or horizontal. For additional protection, a pressure relief valve may be installed in conjunction with check valves to allow reversing flow to reenter the wet wall. Pressure relief valves must be specially designed for sewage applications. As an alternative to relief valves, a hydro-pneumatic tank may be utilized.

(2) Automatic control valves. In situations where long force mains are required, pipe profiles must conform to existing ground elevations for economic reasons. This normally will result in high points in the force main, with the possibility of water column separation at the high points in the force main, with the possibility of water column separation at the high points during pump shutdown or power failure. The pressures generated when these separated columns come to rest against closed valves or against stagnant columns may be large, and are again determined by paragraph c above. In general, where force mains are greater than 1000 feet in length or contain intermediate high points, and where pumping stations are large in capacity, or static discharge heads are greater than 50 feet, control valves will be automatically operated (1) cone, (2) plug, (3) ball, or (4) butterfly valves. Normal operation of these valves upon pump shutdown, is to slowly close the valve while the pump continues to run. When the valve is closed, a limit switch then stops the pump motor. On power failure, an emergency hydraulic or other type operator closes the valve slowly. The time of valve closure is of utmost importance. Valves should be half closed when the velocity in the force main has dropped to zero. The time required to reach zero velocity can be calculated with the following formula:

$$t = LV/g H_{av}$$

where

t = time in seconds

L = length of force main in feet

V = velocity of fluid in pipeline in feet per second, and

H_{av} = average decelerating head including pipe friction in feet

The types of valve operators most often utilized are hydraulic, electric and pneumatic. Valves and operators specified for use will be fully adjustable for closure times ranging from t to $4t$ minimum. In some large pumping stations, the use of automatically controlled valves alone will not be sufficient. Extremely long force mains (over 1 mile) may require very long valve closing times, and thus result in excessive backflow to the wet well and reverse rotation of the pump and motor. To solve these problems, a pump bypass with surge relief valve will generally be required. Valves used for surge relief will be automatically controlled cone or butterfly valves, similar to the pump discharge valves. Normal operation upon pump shutdown now will require the pump discharge valve to be fully closed when the velocity has dropped to zero. The surge relief valve will be fully open allowing backflow to enter the wet well at a reduced rate. As before, the relief valve must close slowly to avoid water hammer. Most cases involving large pump stations with long force mains, which contain several intermediate high points, will be too complex to solve by hand using conventional methods such as graphical solutions, arithmetic integration, or water hammer charts. Many computer programs are now

available for water hammer analysis, and are recommended for use in those instances.

5-6. Screening and comminuting devices.

Centrifugal pumps are susceptible to clogging by rags, trash, and other debris normally found in wastewater. To protect pumps from clogging, equipment will be installed to screen or cut up these materials prior to pumping. Small pump stations with capacities of less than 200 gpm, including grinder pumps and pneumatic ejectors, are exempt from this requirement. The types of equipment to be used include bar racks, screens, and comminutors which are installed in the wet well, or in a separate influent channel. The design of these facilities is covered in TM 5-814-3/AFM 88-11, Vol. 3. At most medium to large sized pump stations, the use of mechanically cleaned bar screens or comminutors will be required. However, at smaller stations in remote areas, manually cleaned racks may be more feasible. The smallest clear opening between bars is normally 1 inch, and spacings of less than $3/4$ inch will not be permitted. All electrically operated equipment in wet wells will have explosion proof motors.

CHAPTER 6

PIPING, VALVES AND APPURTENANCES

6-1. Pipe materials, fittings and joints

a. *General.* Factors to be considered in the selection of pipe materials and piping systems for force mains are: -Flow characteristics or friction coefficient.

- Life expectancy and history of use.
- Resistance to scour and abrasion.
- Resistance to acids, alkalis, high temperature or corrosive wastes, and corrosive soils.
- Ease of handling and installation.
- Physical strength and pressure ratings.
- Joint watertightness and ease of installation.
- Availability of pipe in required sizes, strengths,

etc.

-Availability of fittings, connections and adapters.

No pipe manufactured is suitable for all installation requirements and conditions. The pipe materials covered in this paragraph are the ones most often used for force mains carrying sanitary and industrial wastes. Each type of pipe will be evaluated to determine its suitability for the particular design. Where iron or concrete pipe are to be considered, special attention will be paid to subsurface and soil conditions. The characteristics of the soil in which a pipe is placed affect the rates of corrosion, with the most corrosive soils being those having poor aeration and high values of acidity, electrical conductivity, dissolved salts, and moisture content. The relative potential for corrosion may be estimated by evaluating the degree of corrosion of existing metallic or concrete pipelines previously buried in the soil. Facility engineer personnel will normally have knowledge of these matters. When this information is not available, or is nonconclusive, resistivity tests of the soil will be conducted and results evaluated as required in TM 5-811-4/AFM 88-11, Vol. 4. Pipe materials found inappropriate for use will be deleted from the project specifications.

b. *Ductile iron.* Ductile iron (D.I.) pipe is suitable for force mains used at pumping stations and wastewater treatment facilities. Special uses include river crossings, pipe located in unstable soil, highway and rail crossings, and piping installed above ground. D.I. pipe is susceptible to corrosion from acid wastes and aggressive soils. Cement linings, bituminous coatings or polyethylene linings are usually provided for interior protections. For extremely corrosive soils, a polyethylene encasement is recommended for external protection. Pipe is available in 3-inch through 54-inch diameters, and with mechanical, push-on or flanged joints. Flanged joints are restricted to interior piping.

The Handbook of Ductile Iron Pipe, Cast Iron Pipe published by the Cast Iron Pipe Research Association (CIPRA) will be used for guidance in designing ductile iron force mains.

c. *Steel.* Steel pipe may be used for force mains when lined with cement mortar or bituminous materials to provide internal protection. A bituminous coating must be applied for external protection also. Lined and coated steel pipe is available in diameters 6-inch through 144-inch. Galvanized steel pipe will be used for small diameter force mains and pressure sewers from 1/4-inch to 4-inch in size. Joints for steel pipe less than 6-inch will be threaded. Pipe 6-inch in diameter and larger will have mechanical, push-on, or flanged joints. Threaded and flanged joints will be used only for interior piping. Steel pipe will be installed in accordance with the manufacturer's recommendations, and Manual No. M11-Steel Pipe Design and Installation published by the American Water Works Association (AWWA).

d. *Concrete.* Concrete pressure pipe will generally be used where high strength or large diameter force mains are required. The type of cement used for concrete will be selected in accordance with paragraph 6-5a of TM 5-814-1/AFM 88-11, Vol. 1. Pretensioned reinforced concrete pressure pipe is available in diameters 10-inch through 42-inch, prestressed concrete pressure pipe in diameters 16-inch through 144-inch, and reinforced concrete pressure pipe in diameters 24-inch through 144-inch. Each type utilizes bell and spigot joints with rubber gaskets. The Concrete Pressure Pipe Manual, Manual No. M9 published by the American Water Works Association (AWWA) will be used for design of force mains.

e. *Asbestos-cement.* Force mains constructed of asbestos-cement (A.C.) pressure pipe are durable and light in weight. However, A.C. pipe is affected by corrosive wastes and aggressive soils, and must be provided with plastic linings for protection. The type of material required for A.C. pipe will be type II in accordance with ASTM C 500. Pipe is available in diameters 4-inch through 42-inch, and will be joined by means of couplings utilizing rubber gaskets. Design of A.C. force mains will conform to the manufacturer's recommendations.

f. *Plastic.* Characteristics which make plastic pipe highly desirable for force main use include high corrosion resistance, light weight, and low coefficient of friction. Disadvantages include the possibility of excessive pipe wall deflections when installed

improperly or subjected to high temperature wastes, and chemical breakdown caused by prolonged exposure to sunlight. The following types of plastic pipe are suitable for use:

(1) Polyvinyl chloride (PVC). PVC pipe is available in diameters 4-inch through 12-inch, and with screw, push-on, or solvent weld joints.

(2) Polyethylene (PE). PE pipe may be used in diameters 11/2-inch through 48-inch. Pipe joints consist of mechanical, flanged, or heat fusion type.

(3) Polypropylene (PP). Pipe diameters available with polypropylene pipe are 1/2-inch through 4-inch. All pipe will be joined by heat fusion methods. Screwed and flanged joint pipe will not be used underground. Manufacturer's recommendations will be used in design of plastic pipe, in addition to the Handbook of PVC Pipe-Design and Construction published by the Uni-Bell Plastic Pipe Association.

g. Fiberglass. Fiberglass pipe provides a good alternative for use in large diameter force mains. High structural integrity, low pipe friction coefficient, and a high resistance to internal/external corrosion and to high temperature wastes, are important properties of fiberglass pipe. The following types of fiberglass pipe may be used:

(1) Reinforced thermosetting resin pipe (RTRP). RTRP pipe may be installed in diameters of 6-inch through 144-inch. Jointing systems for RTRP pipe include bell and spigot, flanged, or special mechanical type couplings. Elastomeric gaskets are used to provide flexible joints.

(2) Reinforced plastic mortar pipe (RPMP). Pipe diameters available for RPMP pipe range from 8-inch to 144-inch. Pipe joints are made with grooved couplings or bell and spigot joints utilizing rubber gaskets. Design of fiberglass force mains will follow the manufacturer's recommendations.

h. Interior piping. Pump suction and discharge piping inside the station will normally be ductile iron or steel. However, other pipe materials covered in this paragraph are not precluded from use. Pipe, fittings and joints serving as force mains will be selected to withstand the maximum internal operating pressures, including transient surges, as determined in chapter 5. The project specifications will indicate the appropriate pressure class and rating for each pipe application.

6-2. Valves and appurtenances. The use of valves in wastewater pumping can be divided into the following categories:

a. Isolation or shutoff valves. Where the need to isolate pumps or part of the piping system occurs, manually operated shutoff valves will be used. Gate valves or butterfly valves generally serve as shutoff valves, however ball valves or plug valves may also be used. Shutoff valves are required on the suction and discharge sides of all pumps.

b. Surge control valves. To protect pumps and piping from surges caused by pump shutdown or power failure, gravity operated swing check or ball check valves, or automatically operated cone, plug, ball or butterfly valves will be installed in the pump discharge line. The operation of surge control valves is discussed in paragraph 5-5.

c. Blowoff valves. A valve outlet installed at the low point in a force main, and arranged to drain or flush the pipeline, is termed a blowoff. Normally, blowoffs will be required only on long depressed sections of force main, or where an accumulation of solids is likely to occur. Blowoff connections will be installed in manholes or valve structures, and will be protected against freezing. A means of discharging to a suitable location materials flushed from the system will be provided. The pipe size of the outlet connection should coincide with the size of the force main.

d. Air valves. Air valves will be installed at high points in force mains for the purpose of admitting and releasing air. When the pipeline is taken out of service for draining, flushing and filling operations, a manually operated valve will be adequate. However, where air pockets or pressures less than atmospheric are likely to occur with the pipeline in service and under pressure, automatic air release and/or air vacuum valves will be used. Manual valves can also be used with the pipeline under pressure by leaving the valve partially open. Automatic valves are not recommended due to maintenance problems, and should be used only where absolutely required. Automatic valves will be of a type specially designed for sewage, and will be provided with backflushing connections. All valves will be installed in a manhole or valve structure with adequate drainage and protection against freezing.

6-3. Installation

a. Structural design. Structural design of force mains will be in accordance with the requirements set forth for sewers in chapter 5 of TM 5-811/AFM 88-11, Vol. 1.

b. Thrust restraint. Force mains will be restrained to resist thrusts that develop at bends, tees, wye connections and plugs in the pipe. The magnitude of such forces can be calculated with the use of formulas found in standard hydraulics textbooks. Required methods of restraint will consist of tie rods and clamps, or concrete thrust blocks, and will be designed in accordance with Section VI of the CIPRA Handbook of Ductile Iron Pipe, Cast Iron Pipe.

c. Depth of cover. Force mains will be installed with sufficient depth to prevent freezing, and to protect the pipe from structural damage. A minimum

cover depth of 3 feet will ordinarily be required for freeze protection. However, in unusually cold climates, a greater depth may be required.

d. *Protection of water supplies.* Force mains and pressure sewers will not be installed closer than 10 feet horizontally to potable water lines. If conditions prevent a 10-foot clearance, a minimum distance of 6 feet will be allowed provided the bottom of the water pipe is at

least 12 inches above the top of the pressure pipe. Where a pressure pipe must cross a potable water line, the pressure line will always be installed below the water line with a minimum vertical clearance of 2 feet. Pressure pipe joints will not be closer than 3 feet to the crossing unless fully encased in concrete.

CHAPTER 7

PUMP STATION COMPONENTS

7-1. Construction requirements

a. Station configuration. The space requirements of pumps, piping and equipment, along with the storage volume required in the wet well, will be carefully determined so that the proper size, shape and configuration of the pumping station can be selected. The size and shape of the station will often be dictated by equipment other than pumps, such as bar screens, comminutors, grit collectors, etc. Rectangular or square structures normally have more usable interior space than circular ones, and will be employed whenever possible in the design of medium to large sized pumping facilities. However, where the below ground portion of the station must be made deep to accommodate incoming sewers, and where foundation conditions are poor, circular caisson type structures will be required if lateral earth pressures are excessively high. Factory assembled or package type stations will generally be circular in design, and will be anchored to base slabs where warranted by subsurface conditions. Pump stations located in cold regions or in seismic zones will require special design considerations.

b. Designing for operation and maintenance. The design of medium to large sized, conventional type pumping facilities will include adequate floor openings, doorways, or access hatches for the installation, removal, and replacement of the largest items of equipment. Interior dimensions in the dry well will provide a minimum clearance of 4 feet between adjacent pump casings, and a minimum of 3 feet from each outboard pump to the closest wall. Other major items of equipment will be provided similar spacing. A 7-foot minimum clearance between floor and overhead piping will be maintained where practicable. Smaller package type stations will be furnished with necessary access openings for removal of pumps and equipment, however interior dimensions and clearances will generally be less than for field erected stations. Wet wells for medium to large sized stations will be divided into two or more compartments to facilitate cleaning and repairs. Wet wells for all stations will have no length, width or diameter smaller than 4 feet. Eye bolts or trolley beams will be provided in smaller stations, and overhead bridge cranes in large stations, for hoisting and removing equipment from mountings. Stairs will be provided in medium to large sized stations so that personnel may inspect and maintain equipment. Smaller stations, except those utilizing submersible pumps, will require the use of vertical safety ladders. A suitable means will be provided to service and maintain all equipment. A floor drainage system will be provided in the dry well, and throughout the superstructure, for

collection of wash down, seepage, and stuffing box leakage. These wastes will be piped or conveyed to the wet well, either by gravity or by sump pump. Openings to the wet well and dry well through the main floor of the station will be above the maximum flood level, or will otherwise be protected from flooding.

c. Materials of construction. Large to medium sized, conventional type stations will ordinarily be constructed of reinforced concrete. The above ground portion of the building may be of masonry, wood or metal panel construction. The requirements of Department of Defense (DOD) Construction Criteria Manual 4270.1-M will be followed in designing for fire resistive structures. Small package type stations will generally be manufactured of steel or fiberglass, with separate wet wells constructed of precast concrete or fiberglass manhole sections. Where steel structures are used, cathodic protection or appropriate corrosion control measures will be provided for the underground steel shell in conformance with TM 5-811-4 or AFM 88-45. Alternatively, steel structures may be protected by a concrete or gunite coating where proof can be furnished by the manufacturer of satisfactory design life. All structures will be designed to withstand flotation.

d. Personnel safety. Guards will be placed on and around all equipment where operators may come in contact with moving parts. Railings will be required around all floor openings, and along platforms or walkways, where there is a danger that personnel may fall. Warning signs will be placed at all hazardous locations. Rubber mats will be provided in front of all electrical equipment where the potential exists for electrical shock. Adequate lighting and ventilation will be provided as required in paragraphs 7-2 and 7-3. In attended stations where the possibility exists for toxic, explosive, or otherwise hazardous atmospheres, proper design for personnel safety will be in conformance with chapter 19 of TM 5-814-3/AFM 88-11, Vol. 3. Design for fire protection will be in accordance with DOD Manual 4270.1-M and TM 5-812-1. Wastewater pumping stations will be classified as light hazard, industrial type occupancies.

7-2. Heating and ventilation

a. Heating. All pumping stations subject to possible freezing will be supplied with automatically controlled heaters in the equipment areas. For

unattended stations, temperatures will be maintained at 40 degrees F. Attended stations will be heated to 65 degrees F. Although wet wells are generally unheated, thermostatically controlled heaters may be used to prevent condensation on walls and floors during cool weather, provided the ventilation system is shut off.

b. Ventilation.

(1) Wet wells will be provided with a positive ventilation capacity of 30 air changes per hour during occupancy, based on the wet well volume below grade and above the minimum wastewater level.

(2) Unattended dry wells will be provided with a positive ventilation capacity of 30 air changes per hour. Attended dry wells will be provided with a continuously-operated ventilation capacity of 6 air changes per hour, supplemented with additional ventilation in warm climates to remove pump motor heat to within 5 degrees F. of the outside air temperature. Supply intakes and exhaust outlets must be located properly to introduce fresh air and remove hazardous gases or fumes. The wet and dry well sides of the station will be provided with separate ventilation systems.

7-3. Electrical equipment and lighting. Pump station equipment will be suitable for operation at either 208V, 230V, or 480V, 60 Hz, three phase power supplies. However, equipment with motors smaller than 0.5 horsepower, including meters, switches, timers, clocks, and similar equipment, will be suitable for operation at a 125V, 60 Hz, single phase power source.

a. Service transformers. Service transformer installations will conform to the requirements of TM 5-811-1/AFM 889, Chap. 1.

b. Motor starters and controls. Motor starters and controls will be provided and housed in a factory assembled, free-standing control center located on the ground floor. The center will include motor starters, switches or circuit breakers, instrumentation and controls. A pump station requiring a few small sized starters is an exception, and will employ wall mounted or stand mounted equipment.

c. Control for submersible pumps. Enclosures for submersible pump controls will be installed above grade.

d. Trouble alarms. Local trouble alarms will be provided at all pump stations. Alarms will be annunciated remotely from unattended stations. Alarm systems will be provided with manual silencing.

7-4. Standby power. The requirement for fixed, standby power at wastewater pumping stations will depend upon the type, location, and critical nature of each pumping facility. For stations situated in low lying areas, or in areas remote from a treatment plant, standby capability will be provided if a power outage would result in flooding of the station, overflows at sewer

manholes, backup of wastes into buildings, or any unlawful pollution of the environment, or health hazard to personnel. Pumping stations located at or in conjunction with treatment facilities, such as those required for influent pumping, recycling or bypassing of flows, and pumping of effluent, will require standby power capability if the pumping is essential to critical treatment processes, plant flow control, or is necessary to maintain compliance with the discharge permit. If fixed standby power is required, refer to paragraph 4-2 for design criteria when selecting pump drive units, and descriptions of various arrangements to be used in providing fixed, standby power capability at wastewater pumping stations.

7-5. Water supply. A potable water supply is required at all large pump stations to supply washroom and toilet facilities, hydrants, hose bibs and pump seal systems. A wash basin and toilet facilities will be provided at pump stations which are attended regularly. Hose bibs will be provided in wet wells, dry wells and bar screen rooms. Freeze proof wall hydrants will be required for outdoor use. A positive separation will be maintained between the potable water system and any piping or appurtenances subject to contamination. Warning signs will be posted at all water taps not directly connected to the potable water supply. The positive separation will be accomplished either by providing a break with an air gap, or by installing backflow prevention devices. Air force facilities will comply with AFM 85-21.

7-6. Flow measurement. Flow meters installed to indicate and record the discharge from the pump station, and from individual pumps, will be provided at all medium to large sized stations. A meter installed in the discharge header provides valuable information on the operation of the station, and will be required where pumping capacity is expected to increase significantly in the future. Pressure gages are required on individual pump discharge lines, and on the station discharge header. Elapsed time clocks will be mounted on all pump motor starters. For smaller stations utilizing constant speed pumps, an elapsed time clock may be used in lieu of a pipe mounted flow meter to measure pump discharge. This will also aid in scheduling routine maintenance on the motor since most small stations are unattended. A noncorrodible depth gage installed in the wet well will generally suffice for very small pumps; flows can be estimated from depth measurements taken manually. The types of flow measuring devices to be used for large wastewater pumps of the constant, adjustable or variable speed type, include flow

tubes, venturi meters, magnetic and ultrasonic flow meters.

7-7. Paints and protective coatings. The use of paints and protective coatings at wastewater pumping stations will be in accordance with Water Pollution Control Federation (WPCF) Manual of Practice No. 17. A thorough investigation will be made in the design of protective coating systems. Paint materials selected will be appropriate for the types of surfaces being protected, both submerged and nonsubmerged. Coating systems will be designed to resist corrosion from the wastes being handled, and from gases and vapors present, taking into consideration the expected temperature and

humidity variations within the station. Coating systems will consist of adequate surface preparation, and the application of prime and finish coats using compatible materials as recommended by the coatings manufacturer. All pumps and equipment will receive protective coatings in conformance with the manufacturer's recommendations. All ferrous materials including galvanized surfaces will be protected. Particular care will be taken to protect welds and threads at connections. Package type stations will be shipped to the construction site with factory applied paints and coatings sufficient for the required service.

APPENDIX A REFERENCES

Government Publications

Department of Defense

DOD 4270.1-M

Departments of the Army and the Air Force

TM 5-811-1/AFM 88-9, Ch. 1

TM 5-8114

TM 5-812-1

TM 5-814-1/AFM 88-11, Vol. 1

TM 5-814-3/AFM 88-11, Vol. 3

TM 5814-8

Department of the Air Force

AFM 85-21

AFM 88-45

Construction Criteria Manual

Electric Power Supply and Distribution

Electrical Design: Corrosion Control

Fire Prevention Manual

Sanitary and Industrial Wastewater

Collection-Gravity Sewers and Appurtenances

Domestic Wastewater Treatment

Evaluation Criteria Guide for Water Pollution
Prevention, Control and Abatement Program

Operation and Maintenance of Cross Control and
Backflow Prevention Devices

Civil Engineering Corrosion Control-Cathodic Protection
System

Nongovernment Publications

American Society for Testing and Materials (ASTM): Race St., Philadelphia, PA 19103

C 500

Testing Asbestos-Cement Pipe

American Water Works Association (AWWA), 6666 W. Quincy, Denver, Co 80235

Manual No. M9

Concrete Pressure Pipe (1979)

Manual No. M11

Steel Pipe Design and Installation (1964)

Cast Iron Pipe Research Association (CIPRA), 1301 West 22nd St., Oak Brook, IL 60521

Handbook of Ductile Iron Pipe, Cast Iron Pipe (1978)

Uni-Bell Plastic Pipe Association, 2655 Villa Creek Dr., Suite 150, Dallas, TX 75234

Handbook of PVC Pipe-Design and Construction (1977)

Water Pollution Control Federation (WPCF), 2626 Pennsylvania Ave., NW, Washington, DC 20037

Manual of Practice No. 17

Paints and Protective Coatings for Wastewater
Treatment Facilities (1969)

BIBLIOGRAPHY

- Brater, E. F. and King, H. W., *Handbook of Hydraulics*, 6th ed., McGraw-Hill, New York, 1976.
- Hicks, T. G. and Edwards, T. W., *Pump Application Engineering*, McGraw-Hill, New York, 1971.
- Joint Committee of the Water Pollution Control Federation and the American Society of Civil Engineers, *Wastewater Treatment Plant Design*, WPCF Manual of Practice No. 8, Washington, D.C., 1977.
- Joint Committee of the Water Pollution Control Federation and the American Society of Civil Engineers, *Design and Construction of Sanitary and Storm Sewers*, 2nd ed., WPCF Manual of Practice No. 9, Washington, D.C., 1970.
- Metcalf & Eddy, Inc., *Wastewater Engineering: Collection and Pumping of Wastewater*, McGraw-Hill, New York, 1981.
- Morris, H. M. and Wiggert, J. M., *Applied Hydraulics in Engineering*, 2nd ed., Ronald Press, New York, 1972.
- Water Pollution Control Federation, *Design of Wastewater and Stormwater Pumping Stations*, WPCF Manual of Practice No. FD4, Washington, D.C., 1981.

BIBLIO-1

The proponent agency of this publication is the Office of the Chief of Engineers, United States Army. Users are invited to send comments and suggested improvements on DA Form 2028 (Recommended Changes to Publications and Blank Forms) direct to HQDA (DAEN-ECE-G), WASH D.C. 20314-1000.

By Order of the Secretaries of the Army and the Air Force:

Official:

JOHN A. WICKHAM, JR.
General, United States Army
Chief of Staff

DONALD J. DELANDRO
Brigadier General, United States Army
The Adjutant General

Official:

CHARLES A. GABRIEL, *General USAF*
Chief of Staff

JAMES H. DELANEY, *Colonel, USAF*
Director of Administration

Distribution:

Army: To be distributed in accordance with DA Form 1234B, requirements for TM 54800 Series: Engineering and Design for Real Property Facilities.

Air Force: F

RECOMMENDED CHANGES TO EQUIPMENT TECHNICAL PUBLICATIONS



THEN... JOT DOWN THE
DOPE ABOUT IT ON THIS
FORM, CAREFULLY TEAR IT
OUT, FOLD IT AND DROP IT
IN THE MAIL!

SOMETHING WRONG WITH THIS PUBLICATION?

FROM: (PRINT YOUR UNIT'S COMPLETE ADDRESS)

DATE SENT

PUBLICATION NUMBER

PUBLICATION DATE

PUBLICATION TITLE

BE EXACT... PIN-POINT WHERE IT IS

PAGE
NO.

PARA-
GRAPH

FIGURE
NO.

TABLE
NO.

IN THIS SPACE TELL WHAT IS WRONG
AND WHAT SHOULD BE DONE ABOUT IT:

TEAR ALONG PERFORATED LINE

PRINTED NAME, GRADE OR TITLE, AND TELEPHONE NUMBER

SIGN HERE:

DA FORM 2028-2
1 JUL 79

PREVIOUS EDITIONS
• ARE OBSOLETE.

P.S.—IF YOUR OUTFIT WANTS TO KNOW ABOUT YOUR
RECOMMENDATION MAKE A CARBON COPY OF THIS
AND GIVE IT TO YOUR HEADQUARTERS.

